



**NOTES:**

1. HYDRANTS TO BE MUELLER SUPER CENTURION A423-PN, INLET 6" - 5 1/4" MVO, 1-1/2" PENTAGON OPERATING NUT OPEN LEFT.
2. CITY OF ASTORIA HYDRANTS ARE YELLOW AND PRIVATE HYDRANTS ARE RED.
3. RESTRAIN JOINTS BY USING FLANGED HYDRANT SHOE, SPOOL, AND GATE VALVE -OR- WITH GRIP RING GASKET MJ JOINT RESTRAINTS.
4. ALL FITTINGS IN CONTACT WITH CONCRETE SHALL BE WRAPPED IN PLASTIC. HYDRANT DRAIN HOLES TO REMAIN OPEN TO DRAIN ROCK AND OPERATIONAL.
5. 1 1/2" - 3/4" CLEAN DRAIN ROCK SHALL BE PLACED A MINIMUM OF 6" ABOVE DRAIN OUTLET 1 YD MINIMUM AREA.
6. WHERE PLANTER STRIP EXISTS HYDRANT SHALL BE PLACED SO FRONT PORT IS A MINIMUM OF 24" BEHIND FACE OF CURB.
7. BURY OF HYDRANT SHALL BE MEASURED FROM FINISHED GRADE TO BOTTOM OF CONNECTION PIPE.
8. THRUST BLOCK AT FIRE HYDRANT TEE SHALL HAVE A 3.7 SQ. FT BEARING AREA.
9. HYDRANT VALVE SHALL BE AMERICAN FLOW CONTROL RESILIENT WEDGE GATE VALVE ONLY. SEE DETAIL W-1
10. PIPING BETWEEN HYDRANT AND VALVE TO BE SAME PRESSURE CLASS AS WATER MAIN OR GREATER.
11. HYDRANT MAY NOT BE LOCATED WITHIN 3' OF ANY OBSTRUCTION.



**City of Astoria**  
**Public Works Department**  
 1095 Duane Street

**Fire Hydrant Detail**

Date Adopt. 10/31/2012 Date Rev. 08/07/2023

Dwg. Name: W-2 Fire Hydrant.dwg

DWG. NO.

**W-2**